



OFFICE OF CIVIL SURGEON, AMRITSAR

PHONE 0183 2211864

E-MAIL:- nrhmamritsar@gmail.com





No.SSI/CS/ASR/2023/...../12.....


DATED;...02/05/2023.

Certificate of Cleanliness and Sanitation

*This Is To Certify That We Have Inspected The Premises Of **AKAL ACADEMY BASARKE, AMRITSAR** On 17/04/2023 After Inspecting Their Class Rooms And Toilets. We Certify That Their Cleanliness And Sanitation is Satisfactory. Facility of portable water with R.O. is also available.*


Civil Surgeon, Amritsar


Manager
**AKAL ACADEMY
BASARKE, AMRITSAR**


Principal
**AKAL ACADEMY
BASARKE
Chheharta Sahib (Asr.)**



TC-9815

TEST REPORT						
Name & Address of Customer : Akal Academy Basarke Village-Basarke,P.O-Gumanpura,Near Bagichiwala Bhatha,Amritsar			Customer Reference No.		No : 41/06/2023/GEN/AAB Dated : 05/06/2023	
			Sample Submitted by		S. Sarabjeet	
			Date of Sample Receipt		07/06/2023	
			Analysis Starting Date		07/06/2023	
			Analysis completion Date		08/06/2023	
Discipline : Chemical Testing			Group: Water			
ULR No.:	TC981523000000359F		Sample Type :		Water	
Test Report No.:	RWTLASR/2324/00179		Date of Issue :		04/07/2023	
Registration no.:	RWTLASR/REG2324/01562		Condition of Sample :		Unsealed	
Collection Point:	Private Submersible		Quantity/Type of Bottle:		1000 ml / Plastic Bottles	
Scheme/Source:	Not Mentioned(Not Mentioned)		Location/Depth :		Gumanpura (S/pump 420 ft) / NA	
Village :	Not Mentioned		Habitation :		Not Mentioned	
Block:	Not Mentioned		District :		Amritsar	
Latitude :	Not Mentioned		Longitude:		Not Mentioned	
Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.26	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-1993) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	TDS	436	500	2000	mg/l	IS 3025 (Part 16-1984) Gravimetric Method
5	Turbidity	0.25	1	5	NTU	IS 3025 (Part 10-1984) Nephelometric Method
6	Alkalinity	248	200	600	mg/l	IS 3025 (Part 23-1986) Indicator Method
7	Hardness	204	200	600	mg/l	IS 3025 (Part 21- 2019) EDTA Method
8	Calcium	40.08	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
9	Magnesium	25.27	30	100	mg/l	APHA (23rd Ed.2017) Method: 3500-Mg+2 B By Calculation Method
10	Chloride	15.99	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed), ND=Not Detected
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

(Signature)
Manager

AKAL ACADEMY
BASARKE, AMRITSAR

(Signature)
Principal

AKAL ACADEMY
BASARKE
Chheharta Sahib (Asr)

(Signature)

Mr. Pankaj Kumar
Quality Manager
Authorized Signatory
For,Regional Water Testing Lab
Amritsar

----- End of the Test Report -----